

BRIEFING SESSION Q&A FOR JW RFP 10/05/2024

Q&A

1. W.r.t OHS requirements, are full registration needed?

Yes, persons must be fully registered as Pr CHSA as per the SACPCMP (South African Council for Project and Construction Management Professionals). Candidate registration will not be recognised as sufficient.

2. Will butt/flood-welding be accepted?

No, the specifications call for **electrofusion** welding for HDPE pipes. Contractors are to be familiar with the required works.

3. Does the coupling for the HDPE specified pipe fit inside the steel pipe?

Yes, the specifications call for a 200mm HDPE pipe and there should be sufficient space inside the existing 250mm steel pipe to allow for the couplings to also fit.

4. Will grouting be required?

No, the pipe is meant to be a temporary solution and should fit snugly inside the pipe with little envisaged movement.

5. Environmental and OHS Clarification given my Muano (JW Safety Practitioner).

- a. Persons must be fully registered as CHSO as per the SACPCMP (South African Council for Project and Construction Management Professionals). Candidate registration will not be recognised as sufficient.
- b. The project will require a full-time Environmental Officer, and the EO must hold a National Diploma in Environmental Management or BA/BSc Environmental Management and 3 years working experience.
- c. Construction Site Management and personnel to comply with the requirements of the Occupational Health and Safety Act (85 of 1993), Construction Regulations, 2014 (Government Gazette No. 37305, 7 February 2014)

6. Email enquiry from Mr John Masike - I am requesting a more detailed technical spec on distances to be covered and Bill of quantity.

As stated during the site briefing session, the Bill of Quantities is included in the Request For Pricing that indicate the specification and estimated quantities. Tenderers also to note the following under “General” that covers the Standard form Contract and Standard Specifications.

General:

1. The Standard form Contract applicable is the General Conditions of Contract for Construction Works (Third Edition of 2015) published by SAICE (South African Institute of Civil Engineering)
2. SABS 1200 Standard Specifications are applicable.