



City of Johannesburg

Johannesburg Water SOC Ltd

Turbine Hall
65 Ntengi Piliso Street
Newtown
Johannesburg

Johannesburg Water
PO Box 61542
Marshalltown
2107

Tel +27(0) 11 688 1400
Fax +27(0) 11 688 1528

www.johannesburgwater.co.za

SUPPLY CHAIN MANAGEMENT UNIT

17 December 2024

RE: CLARIFICATION AND RESPONSE CIRCULATION NO.2

NOTICE TO TENDERERS

<u>CLARIFICATION</u>	
<u>CONTRACT NUMBER:</u>	JW 14060RR
<u>CONTRACT TITLE:</u>	Northern Wastewater Treatment Works: Dewatering Building Belt Press Replacement and Associated Ancillaries
<u>DEPARTMENT</u>	JW- SCMU
<u>Email</u>	thapelo.teane@jwater.co.za and gcina.ndela@jwater.co.za

With reference to the above-mentioned tender please note the following clarification.

In accordance with Clause C3.1.1, herewith the amendment “Respond to a request for clarification received up to seven calendar days before the tender closing time stated in the tender data and notify all Tenderers who drew procurement documents” “Respond to a request for clarification received up to seven calendar days before the tender closing time stated in the tender data and notify all Tenderers who drew procurement documents”. The response to the received queries is provided below.

Directors:

Ms Dineo Majavu (Chairperson), Mr Ntshavheni Mukwevho (Managing Director and Executive Director),
Mr Kgaugelo Mahlaba (Chief Financial Officer and Executive Director), Mr Sipho Mthembu, Ms Zandile Meeleso, Mr Pholoso Matjele,
Mr Kgaile Mogoye, Mr Molate Mashifane, Ms Pamela Mabece, Mr Collen Sambo, Mr Makoko Makgonye, Ms Thabiso Kutumela,
Mr Kefiloe Mokoena

Ms Kethabile Mabe (Company Secretary),
Johannesburg Water SOC Ltd
Registration Number: 2000/029271/30



a world class African city



City of Johannesburg

Johannesburg Water SOC Ltd

Turbine Hall
65 Ntengi Piliso Street
Newtown
Johannesburg

Johannesburg Water
PO Box 61542
Marshalltown
2107

Tel +27(0) 11 688 1400
Fax +27(0) 11 688 1528

www.johannesburgwater.co.za

QUERIES		RESPONSES
CL No.	Description (Tenderer)	Description (Employer/ Employer's Agent)
C1	<p>1. We've reviewed the gas sludge supply equipment and pipework drawing JW14060R-ME- 003, and noticed discrepancies between the quantities in the pipe schedule and the sectional drawings:</p> <p>Item 6: The schedule specifies 96 bends, whereas the sectional drawings indicate:</p> <ul style="list-style-type: none">• 12 bends on JW14060R-ME- 003, and• 18 bends on JW14060R-ME- 004, totaling 30 bends. <p>Could you confirm if pricing should align with the pipe schedule provided, or if there will be an opportunity later to adjust quantities based on updated information?</p> <p>Additionally, we seek clarification regarding the welds required for flanges. Should these be calculated based on the number of flanges provided in the schedule, or should we align with the drawings provided?</p>	<p>Pricing should align with the Pipe Schedule Provided, actual quantities will be measured and adjusted at a later stage.</p> <p>Align welds required with the number of flanges in the Schedule, actual quantities will be measured and adjusted at a later stage.</p>
C2		

-End-

Directors:

Ms Dineo Majavu (Chairperson), Mr Ntshavheni Mukwevho (Managing Director and Executive Director),
Mr Kgaugelo Mahlaba (Chief Financial Officer and Executive Director), Mr Sipho Mthembu, Ms Zandile Meeleso, Mr Pholoso Matjele,
Mr Kgaile Mogoye, Mr Molate Mashifane, Ms Pamela Mabece, Mr Collen Sambo, Mr Makoko Makgonye, Ms Thabiso Kutumela,
Mr Kefiloe Mokoena

Ms Kethabile Mabe (Company Secretary),

Johannesburg Water SOC Ltd

Registration Number: 2000/029271/30