



THRUST BLOCK C FOR 90° BEND
SCALE 25



THRUST BLOCK C FOR 90°
BEND SIDE ELEVATION
SCALE 25

THRUST BLOCK THICKNESS = 2000mm
CONCRETE CLASS = 30Mpa
75mm COVER REINFORCEMENT



PLAN
(500mm Ø PIPE)
REINFORCEMENT FOR TRUST BLOCK

MEMBER	No OF	BARS PER MEMB	DIA	LENGTH	TOTAL NUM-BER	MARK	S C	B E N D I N G				
								A	B	C	D	E/r
THRUST BLOCK	3	20	Y32	2200	60	A	34	1950				
LINKS		11	R12	5900	33	B	60	1120	1760			
		22	R10	3150	66	C	60	1120	390			
		44	R10	4200	132	D	60	260	1760			
	8	10	12	16	20	25	32	40	TOT	Date		
R	470	173							643	Det by		
Y							833		833	Ref Dwg		
TOT	470	173					833		1476	Job No		
										BENDING SCHEDULE THRUST BLOCK C		