



- NOTES: REINFORCED CONCRETE**
1. THE APPLICABLE STANDARD SPECIFICATION IS SANS 12006 - 1982 WHICH SHOULD BE READ IN CONJUNCTION WITH THE VARIATIONS AND ADDITIONS CONTAINED IN THE EMA PROJECT SPECIFICATION FOR CONCRETE (STRUCTURAL).
  2. CONCRETE COVER TO REINFORCEMENT AND CONCRETE STRENGTH TO BE AS INDICATED BELOW. COVER IS GIVEN TO THE NEAREST FACE. MINIMUM BAR COVER TO BE MAXIMUM OF BAR DIAMETER AND AS SHOWN BELOW. SPECIFIED COVER TO BE MAINTAINED USING CEMENT MORTAR COVER BLOCKS OR APPROVED PLASTIC SPACERS.
  3. ALL AGGREGATE TO BE 19mm UNLESS OTHERWISE SPECIFIED.
  4. CONCRETE DESIGN MIXES TO BE SUBMITTED TO ENGINEER FOR COMMENTS PRIOR TO CONSTRUCTION.
  5. CUBE TESTS TO BE CARRIED OUT ON SITE AND LOGGED WITH POSITION AND DATE. CUBES TO BE TAKEN FOR EACH TYPE OF ELEMENT, AT LEAST ONE SET DAILY AND AT LEAST ONE SET EVERY 50m.
  6. REINFORCEMENT TO BE IN ACCORDANCE WITH SANS 820 AND SHALL BE BENT IN ACCORDANCE WITH SANS 82.
  7. ALL CAST IN ITEMS SHALL BE FREE OF OIL, GREASE, DIRT OR ANY OTHER MATERIAL WHICH MAY IMPAIR THE BOND WITH THE CONCRETE. CONTRACTOR TO REFER TO ARCHITECT/SPECIALIST DRAWINGS FOR DETAILS/SPECIFICATIONS OF OPENINGS, SLEEVES, CONDUITING, ETC. FOR STORMWATER SEWERAGE AND OTHER SERVICES.
  8. FOUNDATIONS HAVE BEEN DESIGNED FOR AN ALLOWABLE GROUND BEARING CAPACITY OF 1000 kPa.
  9. ALL FOUNDATION EXCAVATIONS TO BE INSPECTED BY THE GEOTECHNICAL ENGINEER PRIOR TO CONCRETING.
  10. REMOVAL OF FORMWORK TO BE IN ACCORDANCE WITH THE PROJECT SPECIFICATION. IT IS THE CONTRACTOR'S RESPONSIBILITY FOR BACK-PROPPING ON MULTI-STORY SLAB CONSTRUCTION.
  11. ALL EXPOSED CORNERS TO BE CHAMFERED 25x25 0 U.N.

**themba**  
Confidence • Trust •

INFRASTRUCTURE CONSULTING  
Tel: 0861themba (843622)  
email: info@themba-africa.com

DESIGNED: KB  
10/02/2021

DRAWN: WM  
30/09/2024

CHECKED: LD  
30/09/2024

APPROVED BY: [Signature]  
DATE

ECSA REG. No. [Blank]

CHECKED BY: [Signature]  
DATE

17 HARRISON STREET  
MARSHALLTOWN  
2107

TEL: (011) 688-1400  
FAX: (011) 688-1529

DIEPSLOOT SEWAGE AQUEDUCT  
BRIDGE 1

DECK 1&7 REBAR DETAIL

SURVEY INFORMATION

PROJECT SURVEYOR: [Blank]  
DATE: [Blank]

CCTV INFORMATION

CCTV COMPANY: [Blank]  
DATE: [Blank]

APPROVAL BY JW DEPOT

CHECKED: [Blank]  
APPROVED BY: [Blank]

APPROVAL BY JW PLANNING

CHECKED: [Blank]  
APPROVED BY: [Blank]

SCALE

AS SHOWN  
A

AMENDMENTS

DESCRIPTION: ISSUED FOR TENDER  
DATE: 30/09/24

CONSULTANTS DWG NO  
13247-02/S/R002/A

DRAWING No.  
JW14455

PROJECT No. [Blank]  
SHEET 2 OF 3

DRAWING No. [Blank]  
REV. A

ORIGINAL PAGE SIZE  
FILE No. [Blank]